



May 13, 2021

Dear Family,

Foundation Academies is committed to ensuring the safety and health of our students, staff, and families. To continue to ensure our community's health and be in compliance with the Department of Education requirements, we recently tested our schools' drinking water for lead. The results from our water samples were received on May 13, 2021.

Results of Our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a thorough plumbing profile for each of our buildings. Through this effort, we identified and tested 11 drinking water and food preparation outlets throughout our school buildings. We are happy to report that all locations continued to test well below the lead action level established by the US Environmental Protection Agency for lead in drinking water (15 µg/l [ppb]).

As always, we can continue to rest assured that our drinking water is safe to consume.

Sincerely,

A handwritten signature in black ink, appearing to read 'Graig Weiss', is positioned below the word 'Sincerely,'.

*Graig Weiss*

Chief Executive Officer  
Foundation Academies



FENNELLY ENVIRONMENTAL ASSOCIATES, LLC

FENNELLY ENVIRONMENTAL  
ASSOCIATES, LLC  
116 VILLAGE BLVD  
SUITE 200  
PRINCETON, NJ 08540  
PHONE: 609-954-8842  
FAX: 609-498-7905  
www.fennellyea.com

May 13, 2021

Mr. Jeffrey Castagne  
Foundation Academies  
363 W. State Street  
Trenton, NJ 08618

Sent via email to: [jtcastagne@foundationacademy.org](mailto:jtcastagne@foundationacademy.org)

**Re: Drinking Water Sample Results  
Foundation Academy Properties  
22 Grand Street and 363 West State Street  
Trenton, New Jersey**

Dear Mr. Castagne:

On April 28, 2021, Fennelly Environmental Associates, LLC (FEA) collected drinking water samples from the above referenced properties for analysis of lead. Drinking water samples were collected from accessible and working water fountains and kitchen food prep areas. A total of 11 drinking water samples were collected at the Foundation Academy schools located at 22 Grand Street and 363 West State Street in Trenton. A field blank was also collected at each school. Sample locations were provided by Foundation Academy.

Analytical results for drinking water samples are presented in the attached tables. Review of analytical results for drinking water samples revealed no concentrations exceeding the New Jersey Department of Environmental Protection (NJDEP) Drinking Water Standard for lead of 15 micrograms per liter (ug/l).

Please do not hesitate to contact me if you have any questions regarding the information provided above. Thank you.

Mr. Jeffrey Castagne  
5/13/2021  
Page 2

Sincerely,

Fennelly Environmental Associates, LLC

A handwritten signature in black ink, appearing to read 'Sandra Szempruch', written in a cursive style.

Sandra Szempruch  
*Project Scientist*

Attachments: Table 1 - Drinking Water Sample Analytical Results, Foundation Academy, 22 Grand Street, Trenton, NJ  
Table 2 - Drinking Water Sample Analytical Results, Foundation Academy, 363 West State Street, Trenton, NJ

Table 1 - Drinking Water Analytical Results

Foundation Academy

22 Grand Street

Trenton, NJ

Sample ID:		3RD FLOOR FOUNTAIN ELEV	2ND FLOOR FOUNTAIN	2ND FLOOR FOUNTAIN	1ST FLOOR FOUNTAIN	22 GRAND KITCHEN	FIELD BLANK 22 GRAND
Lab Sample ID:	NJDEP Drinking Water Standards	JD24258-1	JD24258-2	JD24258-3	JD24258-4	JD24258-5	JD24258-6
Date Sampled:		4/28/2021	4/28/2021	4/28/2021	4/28/2021	4/28/2021	4/28/2021
Matrix:		Drinking Water	Drinking Water	Drinking Water	Drinking Water	Drinking Water	Drinking Water FB
Lead (ug/kg)							
Lead	15	<0.50	<0.50	<0.50	<0.50	2.7	<0.50

Table 2 -Drinking Water Sample Analytical Results

Foundation Academy  
 363 West State Street  
 Trenton, New Jersey

Sample ID:		2ND FLR KITCHEN	2ND FLR FOUNTAIN BOTTLE	1ST FLR FOUNTAIN STAIRS	GROUND KITCHEN	KITCHEN FOUNTAIN	FOUNTAIN BOILER RM GROUND	FIELD BLANK-363
Lab Sample ID:	NJDEP Drinking	845714	JD24257-1	JD24257-2	JD24257-3	JD24257-4	JD24257-5	JD24257-6
Date Sampled:	Water Standards	4/28/2021	4/28/2021	4/28/2021	4/28/2021	4/28/2021	4/28/2021	4/28/2021
Matrix:		Drinking Water	Drinking Water	Drinking Water	Drinking Water	Drinking Water	Drinking Water	Drinking Water FB
Lead (ug/l)								
Lead	15	0.566	<0.50	<0.50	0.556	<0.50	<0.50	<0.50