



September 16, 2022

Dear FAmily,

Foundation Academies is committed to ensuring the safety and health of our students, staff, and families. To continue to ensure our community's health and be in compliance with the department of Education requirements, we recently tested our school's drinking water for lead. The results from our water samples were received on September 14th, 2022.

Results of Our Testing

Following instructions given in technical guidance developed by the New Jersey Department of Environmental Protection, we completed a thorough plumbing profile for each of our buildings. Through this effort, we identified and tested 10 drinking water and food preparations outlets throughout our school buildings. We are happy to report that all locations continued to test well below the lead action level established by the US Environmental Protection Agency for lead in drinking water 15 micrograms per liter (ug/l).

As always, we can continue to rest assured that our drinking water is safe to consume.

Sincerely,

Sheria McRae

Sheria McRae
Chief Executive Officer
Foundation Academies



FENNELLY ENVIRONMENTAL ASSOCIATES, LLC

FENNELLY ENVIRONMENTAL
ASSOCIATES, LLC
116 VILLAGE BLVD
SUITE 200
PRINCETON, NJ 08540
PHONE: 609-954-8842
FAX: 609-498-7905
www.fennellyea.com

September 16, 2022

Mr. Jeffrey Castagne
Foundation Academies
363 W. State Street
Trenton, NJ 08618

Sent via email to: jtcastagne@foundationacademy.org

**Re: Drinking Water Sample Results
Foundation Academy Properties
22 Grand Street and 363 West State Street
Trenton, New Jersey**

Dear Mr. Castagne:

On August 29, 2022, Fennelly Environmental Associates, LLC (FEA) collected drinking water samples from the above referenced properties for analysis of lead. Drinking water samples were collected from accessible and working water fountains. A total of ten (10) drinking water samples were collected at the Foundation Academy schools located at 22 Grand Street and 363 West State Street in Trenton including one sample collected from the associated gym building on Grand Street. Sample locations were provided by Foundation Academy.

Analytical results for drinking water samples are presented in the attached tables. Review of analytical results for drinking water samples revealed no concentrations exceeding the New Jersey Department of Environmental Protection (NJDEP) Drinking Water Standard for lead of 15 micrograms per liter (ug/l).

Please do not hesitate to contact me if you have any questions regarding the information provided above. Thank you.

Mr. Jeffrey Castagne
9/16/2022
Page 2

Sincerely,

Fennelly Environmental Associates, LLC

A handwritten signature in black ink, appearing to read 'Sandra Szempruch', written in a cursive style.

Sandra Szempruch
Project Scientist

Attachments: Table 1 - Drinking Water Sample Analytical Results, Foundation Academy, 22 Grand Street, Trenton, NJ
Table 2 - Drinking Water Sample Analytical Results, Foundation Academy, 363 West State Street, Trenton, NJ

Table 1
 Drinking Water Analytical Results - Foundation Academy
 22 Grand Street
 Trenton, NJ

Sample ID:	NJDEP Drinking Water Standards	FIRST FLOOR FOUNTAIN JD50884-1 8/29/2022 Drinking Water	2ND FLOOR FOUNTAIN RM204 JD50884-2 8/29/2022 Drinking Water	2ND FLOOR FOUNTAIN RM312 JD50884-3 8/29/2022 Drinking Water	3RD FLOOR FOUNTAIN RM303 JD50884-4 8/29/2022 Drinking Water	GYM JD50884-5 8/29/2022 Drinking Water
Lab Sample ID:						
Date Sampled:						
Matrix:						
Lead (ug/l)						
Lead	15	<0.50	2.6	<0.50	<0.50	9.63

Table 2
 Drinking Water Analytical Results - Foundation Academy
 363 W. State Street
 Trenton, NJ

Client Sample ID:	NJDEP Drinking Water Standards	GROUND FLOOR FOUNTAIN KITCHEN	1ST FLOOR FOUNTAIN STAIRWAY 4	1ST FLOOR FOUNTAIN STAIRWAY 3	2ND FLOOR FOUNTAIN	2ND FLOOR FOUNTAIN MASS RM
Lab Sample ID:		JD50885-1	JD50885-2	JD50885-3	JD50885-4	JD50885-5
Date Sampled:		8/29/2022	8/29/2022	8/29/2022	8/29/2022	8/29/2022
Matrix:		Drinking Water	Drinking Water	Drinking Water	Drinking Water	Drinking Water
Lead (ug/l)						
Lead	15	<0.50	<0.50	<0.50	<0.50	<0.50

Foundation Academy
 Drinking Water Analytical Results
 363 W. State Street
 Trenton, NJ

Client Sample ID:	NJDEP Drinking Water Standards	GROUND FLOOR FOUNTAIN KITCHEN	1ST FLOOR FOUNTAIN STAIRWAY 4	1ST FLOOR FOUNTAIN STAIRWAY 3	2ND FLOOR FOUNTAIN	2ND FLOOR FOUNTAIN MASS RM
Lab Sample ID:		JD50885-1	JD50885-2	JD50885-3	JD50885-4	JD50885-5
Date Sampled:		8/29/2022	8/29/2022	8/29/2022	8/29/2022	8/29/2022
Matrix:		Drinking Water	Drinking Water	Drinking Water	Drinking Water	Drinking Water
Lead (ug/l)						
Lead	15	<0.50	<0.50	<0.50	<0.50	<0.50

Foundation Academy
 Drinking Water Analytical Results
 22 Grand Street
 Trenton, NJ

Sample ID:	NJDEP Drinking Water Standards	FIRST FLOOR FOUNTAIN JD50884-1 8/29/2022 Drinking Water	2ND FLOOR FOUNTAIN RM204 JD50884-2 8/29/2022 Drinking Water	2ND FLOOR FOUNTAIN RM312 JD50884-3 8/29/2022 Drinking Water	3RD FLOOR FOUNTAIN RM303 JD50884-4 8/29/2022 Drinking Water	GYM JD50884-5 8/29/2022 Drinking Water
Lead (ug/l)						
Lead	15	<0.50	2.6	<0.50	<0.50	9.63